

Seacon Global

2055 E Warner Road,
Tempe, AZ 85284

Yokosuka - Beverly

Client Project # 1
Samples Received: 12/16/2020

Analytical Report
1219-728

Isotope Dilution Method
PFAS



Enthalpy Analytical, LLC – Ultratrace

Lindsay Boone

O: (910) 212-5855 / F: 910-212-5866


lboone@enthalpy.com / www.enthalpy.com

2714 Exchange Drive, Wilmington, NC 28405

I certify that to the best of my knowledge all analytical data presented in this report:

- Have been checked for completeness
- Are accurate, error-free, and legible
- Have been conducted in accordance with approved protocol, and that all deviations and analytical problems are summarized in the appropriate narrative(s)

This analytical report was prepared in Portable Document Format (.PDF) and contains 21 pages.



QA Review Performed by: Juanica L. Thomas

Report Issued Date: 01/03/2020



Summary of Results



Summary of Results: PFAS			
Enthalpy Ultratrace Batch # 10598			
PFAS			
Analyte	Method Blank ng/L	1 ng/L	2 ng/L
Acids			
PFBA	ND U	ND U	ND U
PFPeA	ND U	ND U	ND U
PFHxA	ND U	322	305
PFFHpA	ND U	61.7	ND U
PFOA	ND U	44.6	ND U
PFNA	ND U	ND U	ND U
PFDA	ND U	ND U	ND U
PFUnA (PFUnDA)	ND U	ND U	ND U
PFDoA (PFDoDA)	ND U	ND U	ND U
PFTriA (PFTriA)	ND U	ND U	ND U
PFTeDA (PFTA)	ND U	ND U	ND U
Sulfonates			
PFBS	ND U	56.0	40.6
PFPeS	ND U	157	66.2
PFHxS	ND U	294	ND U
PFFHpS	ND U	26.4	ND U
PFOS	ND U	456	0.341 J
PFNS	ND U	ND U	ND U
PFDS	ND U	ND U	ND U
4:2 FTS	ND U	ND U	ND U
6:2 FTS	ND U	ND U	2.47
8:2 FTS	ND U	51.9	ND U
Other			
PFOSA (FOSA)	ND U	ND U	ND U
N-MeFOSAA	ND U	ND U	ND U
N-EtFOSAA	ND U	ND U	ND U
HFPO-DA (Gen-X)	ND U	ND U	ND U
Lab Sample ID	MB_10598	1219-728_10598_001D2	1219-728_10598_002D2

原水

処理水

Not Detected. '0'

'0'の意味